

ADDENDUM NO. 1

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

**ROOF REPLACEMENTS
MISSOURI LOTTERY HEADQUARTERS AND
DISTRIBUTION CENTER
JEFFERSON CITY, MO
PROJECT NO. N2007-01**

Bid Opening Date has not changed. Bids are due April 16, 2020, 1:30 pm.

Bidders are hereby informed that the construction plans and/or specifications are modified as follows:

CHANGES:

1.  . The referenced symbol represents the new insulation thickness, not including the cover board, on drawings A-101 and A-102.
2. Omit the metal fascia cover on parapet/fire wall separating the two roofs on drawings A-101 and A-102.
3. TPO Specification 075423, Article 2.2.C is revised to read: FM Global Listing: Roofing, base flashings, and component materials shall follow requirements in FM Global for class 1 or noncombustible construction, for a Fire/Windstorm Classification of **1A-90**.

By the Order of:

Division of Facilities Management
Design and Construction
April 10, 2020