

ADDENDUM NO. 2

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

**Upgrade HVAC and BAS System
Farmington Community Supervision Center
Department of Corrections
Farmington, Missouri
Project NO. C2014-01**

Bid Opening Date: 1:30 PM, Thursday, March 30, 2022 (Not Changed)

Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:

SPECIFICATION CHANGES:

1. REVISE Section 230719, HVAC Piping Insulation, 1.2.B
 - a. ADD 4. Buffer tank and Air Separator
2. REVISE Section 230900, Instrumentation and Controls, 2.1.A, Manufacturer
 - a. ADD controls contractor contact info:
Contact: Brian Schepers C&C Group 573-291-5425
3. REVISE Section 232113, Hydronic Piping, 2.3, I
 - a. Grooved, Mechanical joint fittings are allowed
 - b. Source Limitations: Obtain grooved mechanical-joint fittings and couplings from single manufacturer.
 - c. Joint Fittings: ASTM A536, Grade 65-45-12 ductile iron; ASTM A47/A47M, Grade 32510 malleable iron; ASTM A53/A53M, Type F, E, or S, Grade B fabricated steel; or ASTM A106/A106M, Grade B steel fittings with grooves or shoulders constructed to accept grooved-end couplings; with nuts, bolts, locking pin, locking toggle, or lugs to secure grooved pipe and fittings.
 - d. Couplings: Ductile- or malleable-iron housing and gasket of central cavity pressure-responsive design; with nuts, bolts, locking pin, locking toggle, or lugs to secure grooved pipe and fittings.
4. REVISE Section 24 64 23 Scroll Chiller, 2.1.A
 - a. ADD approved manufacturers:
 - a. LG
 - b. Daikin
 - c. JCI/Qunatech
5. REVISE Section 23 82 16, Hydronic Air Coils, 2.2.A.
 - b. ADD approved manufacturers:
 - a. Daikin

GENERAL COMMENTS:

1. The Pre-Bid Meeting was held Wednesday, March 16th, 2023 followed by a walk-through of the facility. The Pre-Bid Meeting sign-in sheet is attached.

2. Please contact Paul Girouard, Contract Specialist, at 573-751-4797 or paul.girouard.oa.mo.gov for questions about bidding procedures and MBE\WBE\SDVE goals and submittal requirements.
3. **All bids shall be submitted on the bid forms without additional terms and conditions, modifications, or stipulations. Each space on the bid forms shall be properly filled including a bid amount for the alternate. Failure to do so will result in rejection of the bid.**
4. **MBE/WBE/SDVE participation requirements can be found in DIVISION 00. The MBE/WBE/SDVE participation goals are 10%/10%/3%, respectively. All MBE, WBE, and MBE/WBE contractors, subcontractors, and suppliers must be certified by the State of Missouri, Office of Equal Opportunity. No other certifications from other Missouri certifying agencies will be accepted. If a bidder is unable to meet a participation goal, a Good Faith Effort Determination Form must be completed. Failure to complete this process will result in rejection of the bid.**
5. The deadline for technical questions is March 22nd, 2023 at noon.
6. Changes to, or clarification of, the bid documents are only made as issued in the addenda.
7. All correspondence with respect to this project must include the State of Missouri project number as indicated above.
8. Current Planholders list available online at: <https://www.oafmdcplanroom.com/jobs/1711/planholders/c2014-01-upgrade-hvac-bas-community-supervision-center-farmington>
9. Prospective Bidders contact American Document Solutions, 1400 Forum Blvd., Suite 7A, Columbia MO 65203, 573-446-7768 to order official plans and specifications.

END ADDENDUM NO. 2