

ADDENDUM NO. 1

TO: PLANS AND SPECIFICATIONS FOR THE STATE OF MISSOURI

Phase II Electrical Replacement & Replace Generators & Transfer Switches
Algoa Correctional Center
Jefferson City, MO
PROJECT NO. C2402-01

Bid Opening Date: 1:30 PM, July 17th , 2025 (Changed)

Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:

SPECIFICATION CHANGES:

Section 001116 – Invitation For Bid

REVISE: 3.0 A. Until: 1:30 PM, July 17, 2025

Section 262313 – Emergency/Standby Power Systems and Automatic Transfer Equipment

REVISE: 2.2 B.1 Operator Panel. The master control panel shall be provided with at least a 15 Inch full color high resolution resistive touch HMI (Human Machine Interface) operator panel to allow the operator to view the status and control the operation of system. The operator panel shall be provided with the following features and capabilities.

Section 263213.13 – Diesel-Engine-Driven Generator Sets

ADD: 2.1 A. “Blue Star Power Systems Inc.” to the list of acceptable Manufactures

DRAWING CHANGES:

None

GENERAL COMMENTS:

1. The Pre-Bid Meeting was held June 27th, 2025, followed by a walk-through of the project site. The Pre-Bid Meeting sign-in sheet is attached.
2. If an additional site visit is necessary, please contact Marc Lambert, 573-751-3954, marc.lambert@doc.mo.gov who will coordinate with the on-site personnel.
3. Please contact Paul Girouard, contract specialist, at paul.girouard@oa.mo.gov for questions about bidding procedures, MBE/WBE/SDVE goals, good faith effort forms, and bid submittal requirements.
4. All bids shall be submitted on the provided bid forms without additional terms and conditions, modifications, or stipulations. Each space on the bid forms shall be properly filled. Failure to do so will result in rejection of the bid.

ADDENDUM NO. 1


5. MBE/WBE/SDVE participation requirements can be found in DIVISION 00. The MBE/WBE/SDVE participation goals are 0%/0%/3%, respectively. All MBE, WBE, and SDVE contractors, subcontractors, and suppliers must be certified by the State of Missouri, Office of Equal Opportunity. No other certifications from other Missouri certifying agencies will be accepted. If a bidder is unable to meet a participation goal, a Good Faith Effort Determination Form must be completed. Failure to complete this process will result in rejection of the bid.
6. Changes to, or clarification of, the bid documents are only made as issued in the addenda.
7. All correspondence with respect to this project must include the State of Missouri project number as indicated above.
8. Current Planholders list available online at: <https://oa.mo.gov/facilities/bid-opportunities/bid-listing-electronic-plans> Prospective Bidders contact American Document Solutions, 1400 Forum Blvd Suite 7A, Columbia MO 65203, 573-446-7768 to order official plans and specifications.

ATTACHMENTS:

1. Pre-bid Sign in sheet

END ADDENDUM NO. 1

Pre-Bid Meeting Attendance Sheet
Phase II Electrical Replacement & Replace Generators & Transfer Switches
Algoa Correctional Center
Project #: C2402-01
June 27th, 2025 10:00 AM

Name & Title	Company Name & Type of Contracting	MBE/WBE/SDVE Status	Phone	E-Mail Address of Attendee & E-Mail Address of Individual filling out Bid Documents
Shannon Thompson  Project Manager	State of Missouri OA/FMDC		573-257-7137	Shannon.thompson@oa.mo.gov
Joe Coffelt	Doe		573-522-4678	Joe.Coffelt@Doe.mo.gov
James Stepp	DOC - E.T. II		573-751-4004	James.Stepp@doc.mo.gov
Justin Rogers	Brown & Root PM / GC		513 301 4995	Justin.Rogers @ Brownand root.com
Brendan Frazer	OA/FMDC CA		573-508-6122	Brendan.Frazer@Oa.mo.gov
Matt Crook	RTM		618.250.0999	<u>matt.crook@rtmec.com</u>

Pre-Bid Meeting Attendance Sheet
Phase II Electrical Replacement & Replace Generators & Transfer Switches
Algoa Correctional Center
Project #: C2402-01
June 27th, 2025 10:00 AM

Name & Title	Company Name Type of Contracting	MBE/WBE/ SDVE Status	Phone	E-Mail Address of Attendee and E-Mail Address of Individual filling out Bid Documents
Marc Lambert	DOC		573 751-3954	<u>Marc.Lambert@Doc.mo.Gov</u>
Tucker Huebner	FABICK CAT		636-577-2144	<u>Tucker.Huebner@fabickcat.com</u>
Craig Linhardt	Meyer Electric		573-893-2335	<u>Craig@meyerelectric.net</u>
COLE LODGE	KASER ELECTRIC		573-556-6188	<u>Clodge@kasercentralmo.com</u>
Greg Reinhold	Reinhold Electric		314-604-2871	<u>greg@reinholdelectric.com</u>
Mark Palmer	Reinhold Electric		314 562 6104	<u>Mark@reinholdelectric.com</u>

Pre-Bid Meeting Attendance Sheet
Phase II Electrical Replacement & Replace Generators & Transfer Switches
Algoa Correctional Center
Project #: C2402-01
June 27th, 2025 10:00 AM

Name & Title	Company Name Type of Contracting	MBE/WBE/ SDVE Status	Phone	E-Mail Address of Attendee and E-Mail Address of Individual filling out Bid Documents
Scott Harris PM	Lumix Electric	-	816518 1660	Sharris@aLumixelectrical.com
Kyle Kempker Deputy Warden	ACC Admin		573 536 8755	Kyle.Kempker@doc.mo.gov