

ADDENDUM NO. 2

TO: PLANS AND SPECIFICATIONS FOR THE STATE OF MISSOURI

Backup Power Equipment Replacement
Fulton Reception and Diagnostic Center
Fulton, Missouri
Project No.: C2415-01

Bid Opening Date: 1:30 PM, December 2, 2025 (Unchanged)

Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:

SPECIFICATION CHANGES:

None

DRAWING CHANGES:

None

BIDDERS QUESTIONS AND RESPONSES:

1. Will the generator circuit breaker require ERMS??

Response: The generator circuit breaker size is ultimately determined by the generator manufacturer. If the frame or highest current trip setting for the circuit breaker is 1200A or larger it will be required to have ERMS. The same applies to the circuit breakers in the mobile generator connection cabinet.

2. Can the SB1 XFER be service rated and the SB1 main breaker section be eliminated?

Response: This is acceptable as long as the by-pass isolation is still provided for SB1 XFER.

GENERAL COMMENTS:

1. If an additional site visit is necessary, please contact James Welch, 573-592-4040, James.Welch@doc.mo.gov who will coordinate with the on-site personnel.
2. Please contact Paul Girouard, contract specialist, at Paul.Girouard@oa.mo.gov for questions about bidding procedures, MBE/WBE/SDVE goals, good faith effort forms, and bid submittal requirements.
3. All bids shall be submitted on the provided bid forms without additional terms and conditions, modifications, or stipulations. Each space on the bid forms shall be properly filled. Failure to do so will result in rejection of the bid.
4. MBE/WBE/SDVE participation requirements can be found in DIVISION 00. The MBE/WBE/SDVE participation goals are 0%/0%/3%, respectively. All MBE, WBE, and SDVE contractors, subcontractors, and suppliers must be certified by the State of

ADDENDUM NO. 2

Missouri, Office of Equal Opportunity. No other certifications from other Missouri certifying agencies will be accepted. If a bidder is unable to meet a participation goal, a Good Faith Effort Determination Form must be completed. Failure to complete this process will result in rejection of the bid.

5. Changes to, or clarification of, the bid documents are only made as issued in the addenda.
6. All correspondence with respect to this project must include the State of Missouri project number as indicated above.
7. Current Planholders list available online at: <https://oa.mo.gov/facilities/bid-opportunities/bid-listing-electronic-plans> Prospective Bidders contact American Document Solutions, 1400 Forum Blvd Suite 7A, Columbia MO 65203, 573-446-7768 to order official plans and specifications.

ATTACHMENTS:

NONE

END ADDENDUM NO. 2