

## ADDENDUM NO. 03

**TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI**

Replace Fire Alarm System, Infrastructure  
Boonville Correctional Center  
PROJECT NO.: C2502-01

Bid Opening Date: **1:30 PM, Thursday, September 03, 2026**

---

**Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:**

**SPECIFICATION CHANGES:**

1. NONE

**DRAWINGS CHANGES:**

1. SHEET F-GN-01 – FIRE ALARM GENERAL NOTES

- a. Revise General Note #2, items a, b, c, and d, to read as follows:

ALL WORK SHALL BE DESIGNED, INSTALLED, AND TESTED IN COMPLIANCE WITH THE CODES, STANDARDS, AND AMENDMENTS ADOPTED BY THE STATE OF MISSOURI AND THE CONTRACT DOCUMENTS. PROJECTS DESIGNED THROUGH THE DIVISION OF FACILITIES MANAGEMENT, DESIGN AND CONSTRUCTION SHALL BE DESIGNED IN ACCORDANCE WITH THE LATEST EDITION OF CODES AND STANDARDS PUBLISHED BY THE FOLLOWING:

- a. **2024** INTERNATIONAL BUILDING CODE
- b. **2024** INTERNATIONAL FIRE CODE
- c. OCCUPATIONAL SAFETY AND HEALTH ACT (OSHA)
- d. NATIONAL FIRE PROTECTION ASSOCIATION
  - **2025** NFPA 70 – NATIONAL ELECTRICAL CODE
  - **2026** NFPA 72 – NATIONAL FIRE ALARM AND SIGNALING CODE
  -

2. SHEET F-GN-01 – FIRE ALARM GENERAL NOTES

- a. Add General Note #48 as follows:

TAMPER SWITCHES ARE SOLEY “STAND-ALONE” EXTERNAL TAMPERS FOR OS&Y GATE VALVES. TOTAL COUNTS ARE THE FOLLOWING:

- STAND-ALONE EXTERNAL TAMPERS: 13

**GENERAL COMMENTS:**

1. Questions related to bid submittal and or the bid forms should be directed to the Contract Specialist at the following contact information:
  - a. Email: Paul.Girouard@oa.mo.gov Phone #: (573)680-8543

**ATTACHMENTS:**

- A. NONE

**August 26, 2026**

**END ADDENDUM 03**