

ADDENDUM NO. 2

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

Replace Rooftop Units
New Dawn State School
Sikeston, Missouri
PROJECT NO.: E1905-01

Bid Opening Date: 1:30 PM, December 15, 2022 (Not Changed)

Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:

DRAWING CHANGES:

1. Drawing M-102
 - a. ADD the following note near RTU-4:

Contractor shall remove and return RTU-4 to Owner. Contractor shall protect the RTU for owner to salvage and reinstall at another location. Coordinate removal with owner.
 - b. Add the following note near RTU-5:

Contractor shall remove and return RTU-4 to Owner. Contractor shall protect the RTU for owner to salvage and reinstall at another location. Coordinate removal with owner.
2. Drawing M-103
 - a. ADD the following note near Mechanical Room 107:

Contractor shall install outdoor air sensors per manufactures requirements on a north facing wall minimizing direct sunlight.

SPECIFICATION CHANGES:

(none)

GENERAL COMMENTS:

(none)

ATTACHMENTS:

(none)

END ADDENDUM NO. 2