

ADDENDUM NO. 3

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

Camp Avery – Replace Fire Sprinkler System, Multiple Assets
Camp Avery – 198 Avery Ln
Troy, Missouri 63379
PROJECT NO.: H2001-01

Bid Opening Date: Changed to 1:30 PM, December 6, 2022

Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:

SPECIFICATION CHANGES:

None

DRAWING CHANGES:

1. Sheet FP1.0 – Sheet Not Re-issued
 - a. Removed note #8 from the Fire/Jockey Pump Schedule.

GENERAL COMMENTS:

Response to Bidder Questions:

1. On Sheet FP0.1 under the Fire/Jockey pump schedule note #8, states the GC would be responsible to replace the emergency generator if not large enough is included in the bid. Is that an accurate note? To calculate the correct sizes that he would need a flow test that is not over a year old.

Note #8 in the Fire/Jockey Pump Schedule is not applicable. Note has been removed from the schedule in this Addendum.

ATTACHMENTS:

None

END OF ADDENDUM NO. 3