

ADDENDUM NO. 02

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

Replace HVAC, Multiple Assets
Fulton Treatment Center
Fulton, Missouri
PROJECT NO.: H2404-01

Bid Opening Date: 1:30 PM, Thursday, November 20, 2025 (Unchanged)

Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:

SPECIFICATION CHANGES:

1. NONE

DRAWINGS CHANGES:

1. Sheet M-001

- a. REVISE Hydronic Construction Note 4 as follows:

“Contractor shall provide new heating deionized water with 50 percent (By Volume) inhibited propylene-glycol heat transfer fluid equal to dowfrost fluid.”

2. Sheet M-501

- a. ADD note to detail 8 as follows:

Coupon Rack shall be Manufactured by:

- a. Cannon Water Technology Inc.
 - b. Pacific Sensor Services LLC
 - c. Metex Corporation
 - d. Approved equal

3. Sheet M-601

- a. REVISE Boiler Schedule Note 2 to say “50% Glycol Water Solution”

GENERAL COMMENTS:

1. NONE

END ADDENDUM 02