

## **Addendum No. 02**

TO: PLANS AND SPECIFICATIONS FOR:

Replace Fire Alarm System, Infrastructure  
St. Louis Psychiatric Rehabilitation Center  
St. Louis, MO  
Project No: M2012-01

Bid Opening Date:

Unchanged: 1:30 PM, Thursday, July 23, 2020

---

**BIDDERS ARE HEREBY INFORMED THAT THE CONSTRUCTION PLANS AND/OR SPECIFICATIONS ARE MODIFIED AS FOLLOWS:**

**1. SPECIFICATIONS:**

**A. SECTION 283100– FIRE DETECTION AND ALARM  
MODIFY Article 1.2C as follows:**

**C. Equipment Installer Qualifications.**

1. The fire alarm equipment installer shall have a NICET level 4 certified individual on staff responsible for overseeing the technical design and engineering functions related to the fire alarm system. The NICET level 4 certificate number must be submitted to the engineer with shop drawing submittals.
2. The fire alarm equipment installer shall have on staff NICET level 2 technicians supervising the final connections and programming of the system.

**2. PLANS:**

(none)

**3. GENERAL:**

(none)

**END OF ADDENDUM 02**