

ADDENDUM NO. 2

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

**St. Louis Forensic Treatment Center – South
St. Louis, Missouri
PROJECT NO.: M2207-01**

Bid Opening Date: 1:30 PM, Thursday, April 4, 2024 (Not Changed) Bidders

are hereby informed of the following:

BID FORM CHANGES:

NO CHANGES

SPECIFICATION CHANGES:

1. Section 087100.10-3 – Door Hardware 2.3.D.3., revise as follows:

“Shall be core keyed switches with contractor providing cores and keys to switches.”

2. Section 087100.10-4 – Door Hardware 2.3.G.3., revise as follows:

“Cabling shall be secured to the existing structure with the overhead ceiling space a foot away, at a minimum, from the facility’s main electrical wires, running parallel with all cabling. The cabling is not required to be in a conduit.”

DRAWING CHANGES:

NO CHANGES

GENERAL:

1. All client bathroom doors within the Wards will include the instillation of optical obstruction alert devices at the top and bottom of door. No other doors will have the optical obstruction alert devices installed for this project.

ATTACHMENTS:

NO ATTACHEMENTS

March 27, 2024

END OF ADDENDUM NO. 2