

ADDENDUM NO. 1

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

Building 472A Latrine Replacement
Camp Clark Training Site
Nevada, Missouri
PROJECT NO.: T2036-01

Bid Opening Date: 1:30 PM, Thursday, May 20, 2021 (Not Changed)

Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:

SPECIFICATION CHANGES:

1. Section 07 4000 Metal Roof & Wall Panels

a. Revise Paragraph 2.1.A, as follows:

A. *Metal Roof Panels: Varco-Pruden, MBCI, Firestone, Butler, field fabricated or approved equal. Basis of Design is existing metal roof panels on adjacent buildings, SL1750 concealed fasteners, 16" x 1.75" panel with hidden clips. Provide special weathertightness warranty for 10 years from the date of Substantial Completion and special panel finish warranty for 25 years from date of Substantial Completion.*

b. Revise Paragraph 2.2.A.1, as follows:

1. *The exposed metal roof covering shall be 24 gage (minimum) commercially pure aluminum-coated or zinc-aluminum coated steel panels of such configuration to provide the specified load carrying capabilities and deflection requirements of this specification. Lap panels as directed by manufacturer. Provide in standard color as selected by Architect. Panel dimensions: 16" x 1.75" seam height, mechanically seamed.*

2. Section 10 2114 – Solid Phenolic Core Toilet Partitions

a. ADD *Scranton Products* to Paragraph 1.2.A.

3. Section 22 3400 – Fuel Fired Domestic Water Heaters

a. ADD Paragraph 2.2.A.1.e. as follows:

e. *Heat Transfer Products (Phoenix)*

DRAWING CHANGES:

1. Sheet A-201

a. REVISE Details A, B, C, & D 'Basis of Design: MBCI Superlok Panel' notes as follows:

'Basis of Design: Existing metal roof panels on adjacent buildings, similar to SL1750 16" x 1.75" standing seam'

GENERAL COMMENTS:

1. The Pre-Bid Meeting was held May 05, 2021 followed by a walk-through of the project site. The Pre-Bid Meeting sign-in sheet is attached.
2. Please contact Paul Girouard, Contract Specialist, at 573-751-4797 or paulgirouard@oa.mo.gov for questions about bidding procedures and MBE\WBE\SDVE goals and submittal requirements.
3. **All bids shall be submitted on the bid forms without additional terms and conditions, modifications, or stipulations. Each space on the bid forms shall be properly filled. Failure to do so will result in rejection of the bid.**
4. **MBE/WBE/SDVE participation requirements can be found in DIVISION 00. The MBE/WBE/SDVE participation goals are 10%/10%/3%, respectively. All MBE, WBE, and MBE/WBE contractors, subcontractors, and suppliers must be certified by the State of Missouri, Office of Equal Opportunity. No other certifications from other Missouri certifying agencies will be accepted. If a bidder is unable to meet a participation goal, a Good Faith Effort Determination Form must be completed. Failure to complete this process will result in rejection of the bid.**
5. The deadline for technical questions was May 12, 2021 at noon.
6. Changes to, or clarification of, the bid documents are only made as issued in the addenda.
7. All correspondence with respect to this project must include the State of Missouri project number as indicated above.
8. Current Planholders list available online at: <https://www.oafmdcplanroom.com/jobs/879/details/t2036-01-building-472a-latrine-replacement-camp-clark>
9. Prospective Bidders contact American Document Solutions, 1400 Forum Blvd Suite 7A, Columbia MO 65203, 573-446-7768 to order official plans and specifications.

ATTACHMENTS:

1. Pre-Bid Meeting Sign-In Sheet

May 13, 2021

END ADDENDUM NO. 1



MO National Guard: Building 472A Latrine Replacement
 Project No. T2036-01 Camp Clark Training Site

PRE-BID MEETING – Record of Attendance

May 05, 2021

Name	Company	Phone	Fax	E-Mail
Colton Mariou	CSG	417-592-9955		Colton@Marionllc.net colton@marionllc.net
JOE STOCKMANN	BARTELS-MISSEY	314-320-9252		Joe@BARTELSMISSEY.COM
Cody Block	OA-FMDC	573-298-1980		cody.block@oa.mo.gov
Craig Boeck	OA-FMDC	573-751-7831		Craig.boeck@oa.mo.gov
Jeremy Newton	MONG	573-308-6894		jeremy.l.newton.nfy@mail.mil
DAVID FROHLING	GHN	417-616-1593		df@ghnae.com
Mark Pires	Diggins Co	417-321-6504		
Paul Dyer	Dygim Co	417 321 4357		ddiggins1964@gmail.com
KEVIN SMITH	Flowmaster Construction	573 721-6021		ksbugout@sbcg/dba/NET
Kim Smith	KLS Paving "WBE"	573 581-2051	WBE	kellsmith@kbspaving.com
John Oke Thomas	OKE THOMAS	417 863-6262	MBE	JOHN@OKE-THOMAS.COM