

ADDENDUM NO. 2

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

Exterior LED Street Lighting
Ike Skelton Training Site
Jefferson City, Missouri
PROJECT NO.: T2039-01

Bid Opening Date: 1:30 PM, Thursday, August 19, 2021 (Not Changed)

Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:

SPECIFICATION CHANGES:

1. Section 260533 – Raceway and Boxes for Electrical Systems
 - a. ADD Paragraph 2.1-C as follows:
 - C. HDPE conduit shall be heavy wall, Schedule 40, UL listed under Standard 651B. Conduit shall be suitable for use with 90 degree C insulated wire.
 - b. REVISE Paragraph 3.1-A.2 as follows:
 2. Underground Conduit: Schedule 40 PVC or HDPE.
 - c. REVISE Paragraph 3.1-C as follows:
 - C. Directional Bores: A rigid metal conduit carrier pipe shall be supplied for each PVC or HDPE conduit directional bore under a roadway.

DRAWINGS CHANGES:

1. Sheet G002
 - a. REVISE General Note 18 as follows:
 18. All underground conduit shall be 1-1/4" Schedule 40 PVC or HDPE unless noted otherwise. All aboveground conduit shall be rigid metal. Trenching or directional boring are acceptable methods of underground conduit installation.
2. Sheet E101
 - a. REVISE Obstruction Light (Tag LF-02) model number within Light Fixture Schedule to reflect correct voltage (120V). Correct model numbers are as follows:

Make: Cooper Crouse-Hinds; Model: OWLFSR/120.
Make: Dialight; Model: 860-1R01-001.
Make: Hughey & Phillips; Model: 12004-860-1R01-001.

GENERAL COMMENTS:

1. Bidders who wish to perform a site inspection should contact Missouri National Guard Project Manager Joseph Schaefer at (573) 638-9500 ext 39692 or joseph.e.schaefer10.nfg@mail.mil to schedule a time to enter the facility.
2. Please contact Mandy Roberson, Contract Specialist, at (573) 522-0074, Mandy.Roberson@oa.mo.gov for questions about bidding procedures, MBE\WBE\SDVE Goals, and other submittal requirements.
3. The deadline for technical questions was August 11, 2021.
4. Changes to, or clarification of, the bid documents are only made as issued in the addenda.
5. All correspondence with respect to this project must include the State of Missouri project number as indicated above.
6. Current Planholders list is available online at: <https://www.oafmdcplanroom.com/jobs/1011/plan-holders/t2039-01-exterior-led-street-lighting-ike-skelton-training-site>
7. Prospective Bidders contact American Document Solutions, 1400 Forum Blvd Suite 7A, Columbia MO 65203, (573) 446-7768 to get plans and specifications.
8. **All bids shall be submitted on the bid form without additional terms and conditions, modifications, or stipulations. Each space on the bid form shall be properly filled including a bid amount for each alternate. Failure to do so will result in rejection of the bid.**
9. **MBE/WBE/SDVE participation requirements can be found in DIVISION 00. The MBE/WBE/SDVE participation goals are 10% / 10% / 3% respectively. Only certified firms as of the bid opening date can be used to satisfy the MBE/WBE/SDVE participation goals for this project. If a bidder is unable to meet a participation goal, a Good Faith Effort Determination Form must be completed. Failure to complete this process will result in rejection of the bid.**

August 12, 2021

END ADDENDUM NO. 2