

ADDENDUM NO. 2

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

Replace Concrete Driveway
Higginsville Veterans Cemetery
Higginsville, Missouri
PROJECT NO.: U2603-01

Bid Date is: 1:30 PM, June 4, 2026 (NOT CHANGED)

Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:

SPECIFICATION CHANGES

1. Section 321313 Concrete Paving:
 - a. REVISE Article 2.4-A-1 to read as follows:
 - i. "Portland Cement: ASTM C 150/C 150M Portland cement Type I."
 - b. ADD The following article:
 - 3.9 FIELD QUALITY CONTROL
 - A. Testing Agency: Contractor shall engage a qualified testing agency to perform tests and inspections.
 - B. Testing Services: Testing of composite samples of fresh concrete obtained according to ASTM C 172 shall be performed according to the following requirements:
 1. Testing Frequency: Obtain at least one composite sample for each 100 cu. yd. or fraction thereof of each concrete mixture placed each day.
 - a. When frequency of testing will provide fewer than five compressive-strength tests for each concrete mixture, testing shall be conducted from at least five randomly selected batches or from each batch if fewer than five are used.
 2. Slump: ASTM C 143; one test at point of placement for each composite sample, but not less than one test for each day's pour of each concrete mixture. Perform additional tests when concrete consistency appears to change.
 3. Air Content: ASTM C 231, pressure method; one test for each composite sample, but not less than one test for each day's pour of each concrete mixture.

4. Concrete Temperature: ASTM C 1064; one test hourly when air temperature is 40 deg F and below and when it is 80 deg F and above, and one test for each composite sample.
 5. Compression Test Specimens: ASTM C 31; cast and laboratory cure one set of three standard cylinder specimens for each composite sample.
 6. Compressive-Strength Tests: ASTM C 39; test one specimen at seven days and two specimens at 28 days.
 - a. A compressive-strength test shall be the average compressive strength from two specimens obtained from same composite sample and tested at 28 days.
- C. Strength of each concrete mixture will be satisfactory if the average of any three-consecutive compressive-strength tests equals or exceeds specified compressive strength and no compressive-strength test value falls below specified compressive strength by more than 500 psi. If only one compressive strength test is conducted the compressive-strength must meet or exceed the specified compressive strength.
- D. Test results shall be reported in writing to engineer, concrete manufacturer, and contractor within 48 hours of testing. Reports of compressive-strength tests shall contain Project identification name and number, date of concrete placement, name of concrete testing and inspecting agency, location of concrete batch in Work, design compressive strength at 28 days, concrete mixture proportions and materials, compressive breaking strength and type of break for both 7- and 28-day tests.
- E. Additional Tests: Testing and inspecting agency shall make additional tests of concrete when test results indicate that slump, air entrainment, compressive strengths, or other requirements have not been met, as directed by engineer.
- F. Concrete paving will be considered defective if it does not pass tests and inspections.
- G. Additional testing and inspecting, at contractor's expense, will be performed to determine compliance of replaced or additional work with specified requirements.
- H. Prepare test and inspection reports.

DRAWINGS CHANGES: None

GENERAL COMMENTS:

1. The Pre-Bid Meeting was held May 11, 2026, followed by a walk-through of the site. The Pre-Bid Meeting sign-in sheet is attached.
2. Bidders needing additional site inspection should contact David Smith at 660-362-6109 to schedule a date and time.

3. Please contact Paul Girouard, Contract Specialist, at 573-680-8543 or paul.girouard@oa.mo.gov, for questions about bidding procedures and MBE\WBE\SDVE goals and submittal requirements.
4. The deadline for technical questions by **Close of Business on May 28, 2026**.
5. Changes to, or clarification of, the bid documents are only made as issued in the addenda.
6. Quantities are shown on documents are estimations. The Contractor is responsible for verifying all quantities and no additional payment will be made if final quantities do not match documents.
7. All correspondence with respect to this project must include the State of Missouri project number as indicated above.
8. Current Planholders list available online at: <https://oa.mo.gov/facilities/bid-opportunities/bid-listing-electronic-plans> - U2603-01 Replace Concrete Driveway, Higginsville Veterans Cemetery, Higginsville, Missouri : State of Missouri Office of Administration Prospective Bidders contact American Document Solutions, 1400 Forum Blvd Suite 1C, Columbia MO 65201, 573-446- 7768 to order official plans and specifications.
9. All bids shall be submitted on the bid form without additional terms and conditions, modifications, or stipulations. Each space on the bid form shall be properly filled including a bid amount for the alternates. Failure to do so will result in rejection of the bid.
10. MBE/WBE/SDVE participation requirements can be found in DIVISION 00. The MBE/WBE/SDVE participation goals are 10%/10%/3%, respectively. Only certified firms as of the bid opening date can be used to satisfy the MBE/WBE/SDVE participation goals for this project. If a bidder is unable to meet a participation goal, a Good Faith Page 2 of 2 Effort Determination Form must be completed. Failure to complete this process will result in rejection of the bid.

By the Order of:
Brad Schaefer, Project Manager
Division of Facilities Management,
Design and Construction
May 29, 2026

END ADDENDUM NO. 2