

ADDENDUM No. 4

TO: PLANS AND SPECIFICATIONS FOR:

Replace Security System
South East Correctional Center-Charleston
Project No C1804-01

BIDDERS ARE HEREBY INFORMED THAT THE CONSTRUCTION SPECIFICATIONS ARE MODIFIED AS FOLLOWS.

Revised Bid Opening Date: **1:30 P.M. (CST), Thursday, January 13, 2022.**

GENERAL

1. None.

SPECIFICATION CHANGES:

1. Section 282000; 2.6;
 - a. Revise B to read: "The video encoder shall support AHD, CVI, TVI, and CVBS at full camera resolution, input and output, minimum 15 fps. Encoder output shall provide full image resolution of each input channel without reduction in quality."
 - b. Add H to read: "Approved Manufacturers must provide products meeting the project's device performance specifications. Approval as a manufacturer does not grant approval of a manufacture's entire product line."

PLAN CHANGES:

1. T-401;
 - a. Revised SECURITY PLAN NOTE 8 to permit reconditioning/reuse of existing cabinets. Note 8 now reads:
"REMOVE EXISTING CABINETS AND COMPONENTS. RETAIN CABLING. INSTALL NEW PROGRAMMABLE LOGIC CONTROL SYSTEM, FIBER OPTIC PANELS, NETWORK SWITCH, PAGING AMPLIFIERS, INTERCOM EQUIPMENT, UNINTERRUPTIBLE POWER SUPPLY. CABINET MAY BE RESTORED IN-PLACE TO INCLUDE CLOSURE OF ALL UNUSED OPENINGS, THROUGH CLEANING, REPLACEMENT OF ANY AND ALL MISSING PARTS INCLUDING, BUT NOT LIMITED TO, SIDE PANELS, TOPS, AND DOORS. RE-USED AND REPLACEMENT PARTS MUST MEET THE CURRENT PROJECT SPECIFICATION REQUIREMENTS, LOOK AND PERFORM AS THOUGH NEW."

ATTACHMENTS:

1. None.

END OF ADDENDUM NO. 4

January 11, 2022