

## ADDENDUM NO. 01

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

Replace 6 Gates & Controllers, Fulton Reception Diagnostic Correctional Center  
Fulton, MO  
PROJECT NO. C1918-01

**Bid Opening Date: 1:30 PM, Thursday, March 3, 2022 (Not Changed)**

**Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:**

### **SPECIFICATION CHANGES:**

1. Section 00116 – INVITATION TO BID:

- a. Revise paragraph 4.0.A to remove proposals for “Design Services”

The project includes ~~Design services to~~ the replacement of six (6) existing gates, controllers, and associated wiring at Fulton Reception and Diagnostic Center (FRDC).

2. Section 011000 – SUMMARY OF WORK

- a. Add subparagraph 1.5.C.1.a to read:

Provide the Department of Corrections (DOC) 24 hour notice prior to having any aerial equipment such as a man basket lift on the gate 13 closed side area so that DOC staff can prepare for and coordinate the de-energizing of the lethal fence for safety.

3. Section 323113.34 CHAIN DRIVEN SLIDING GATE OPERATORS FOR CORRECTIONAL FACILITIES (GATE 13):

- a. *Revise paragraph 2.1.E to read as follows and eliminate subparagraphs 2.1.E.1-3:*

E: Motor Housing and Chain tube: Reuse existing.

### **DRAWING CHANGES:**

1. Drawing A206:

- a. Revise Keynote 01 to read:

CHAIN DRIVEN OPERATOR AND ENCLOSURE - RETAIN ENCLOSURE AND REMOVE AND SALVAGE OPERATOR TO OWNER. INSTALL NEW CHAIN DRIVEN OPERATOR.

- b. Revise Keynote 07 to read:

CHAIN TUBE - RETAIN TUBE AND REMOVE AND REPLACE CHAIN

## COMPONENETS

### 2. Drawing E1.1:

- a. Revise note 1 and 2 to change the word "CONTROLLER" to "OPERATOR".
- b. Keynote 2: Remove last sentence (PAINT STEEL BASES ON GATES 3, 4, AND 13).
- c. At Gate 13, add keynote 3 to read:

REPAIR EXISTING CONTROL CONDUIT FROM BOTTOM OF MOTOR OPERATOR  
INTO THE GROUND

### **GENERAL:**

1. Copy of the Pre-Bid meeting Attendance Record is attached for information only. Changes to, or clarification of, the Bid Documents are only made as issued in the Addenda.

**END ADDENDUM NO. 01**

**Pre-Construction Meeting Attendance Record**  
**C1918-01 Fulton Reception Diagnostics & Correctional Center - Gates**  
 February 14, 2022

| Attendee Name / Position                          | Sign-in (Initial) | Company / Department  | Phone                  | Email  |
|---|-------------------|---|------------------------|--|
| Nick Borgmeyer<br>Architect / Project Manager     | NBB               | Simon Oswald Architecture                                   | 573.443.1407<br>x203   | <a href="mailto:borgmeyer@soa-inc.com">borgmeyer@soa-inc.com</a>             |
| Shannon Thompson<br>Project Manager               | ST                | State of Missouri<br>OA / FMDC                              | 573-526-3166           | <a href="mailto:shannon.thompson@oa.mo.gov">shannon.thompson@oa.mo.gov</a>   |
| Frank Cunningham<br>Project Manager               | FC                | State of Missouri<br>OA / FMDC                              | 573-526-3309           | <a href="mailto:frank.cunningham@oa.mo.gov">frank.cunningham@oa.mo.gov</a>   |
| Greg Wykes<br>FOM / Energy Management Coordinator | GW                | State of Missouri<br>Dept of Corrections                    | 573-526-6512           | <a href="mailto:greg.wykes@doc.mo.gov">greg.wykes@doc.mo.gov</a>             |
| James Welch<br>Specialized Trades Supervisor      |                   | State of Missouri<br>Fulton Reception and Diagnostic Center | (573) 592-4040<br>x451 | <a href="mailto:james.welch@doc.mo.gov">james.welch@doc.mo.gov</a>           |
| Jesse Rollins                                     | JR                |   |                        | <a href="mailto:jesse.rollings@oa.mo.gov">jesse.rollings@oa.mo.gov</a>       |
| Danielle Rees Designer                            | DR                | Lumix Electrical  | 573-268-7655           | <a href="mailto:DRees@lumixelectrical.com">DRees@lumixelectrical.com</a>     |
| Scott Weber                                       | SW                | FRDC Warden   | 592-4040               | <a href="mailto:Scott.Weber@doc.mo.gov">Scott.Weber@doc.mo.gov</a>           |
| Stephen Devstine                                  | SD                | FRDC Maint.   | 592-4040               | <a href="mailto:stephen.Devstine@Doc.mo.gov">stephen.Devstine@Doc.mo.gov</a> |
| Kelsey Bealer                                     | KB                | FRDC Maint  | 592-4040<br>ext. 452   | <a href="mailto:kelsey.bealer@doc.mo.gov">kelsey.bealer@doc.mo.gov</a>       |
| Ryan Buschjost                                    | RB                | Meyer Electric  | (573)<br>619-8203      | <a href="mailto:rbuschjost.meyer@gmail.com">rbuschjost.meyer@gmail.com</a>   |
| Kyle Te   | KT                | Arete Contracting   | 573<br>694-0748        | <a href="mailto:BIOS@ARETECONTRACTING.COM">BIOS@ARETECONTRACTING.COM</a>     |
|   |                   |   |                        |  |