

## ADDENDUM NO. 2

**TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI**

**Change in Scope Rebid: Upgrade Fire Alarm and Security Systems  
Center for Behavioral Medicine  
Kansas City, Missouri  
PROJECT NO.: M1903-01**

**Bid Opening Date: 1:30 PM, August 25, 2022 (Not Changed)**

**Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:**

### **SPECIFICATION CHANGES:**

1. Section 282300 – Video Surveillance System – Alternate Bid #1
  - a. ADD Bosch as an acceptable manufacturer to the list of manufacturers in paragraph 2.1.C.
  - b. ADD Bosch as an acceptable manufacturer to the list of manufacturers in paragraph 2.20.A.
  - c. ADD Digital Watchdog as an acceptable manufacturer to the list of manufacturers in paragraph 2.20.A.
2. Section 283111 – Fire Alarm and Detection Systems Addressable
  - a. ADD Potter as an acceptable manufacturer to the list of manufacturers in paragraph 2.1.

### **DRAWING CHANGES:**

1. Sheet E-001 – Electrical Symbols List & Abbreviations
  - a. A symbol with an ‘S’ in a circle and a subscript of ‘FA’ shall be added to the symbols list with the description “FIRE ALARM SPEAKER”.
2. Sheet EF-502 – Fire Alarm New Riser Diagram
  - a. The label on the six (6) fire alarm extender panels (FAEP) shall read “New FAEP #x” in lieu of “Existing FAEP #x”.

### **GENERAL COMMENTS:**

(none)

### **ATTACHMENTS:**

(none)

**END ADDENDUM NO. 2**