

ADDENDUM NO. 3

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

**Replace Escalators & Elevators
West and East Parking Garage
Capitol Building, Jefferson City, Missouri
PROJECT NO.: O1910-01**

Bid Opening Date: 1:30 PM, Thursday, January 14, 2021 (Not Changed)

Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:

SPECIFICATION CHANGES:

1. Section 143100 – Escalators
 - a. ADD the following paragraph to 1.04-6 Mechanical system:
 - b. The overhaul and reuse of the existing gearbox and drive is also acceptable.

DRAWING CHANGES:

1. Sheet E-101 – STATE CAPITOL BASEMENT ESCALATOR PLAN
 - a. REVISE Note 5 bullet point one as follows:
 - A SINGLE DRIVE WITH A PLANETARY GEAR TO POWER BOTH STEPS AND HAND RAILS. IT IS ALSO ACCEPTABLE TO REUSE THE EXISTING GEAR BOX AND DRIVE IF OVERHAULED.

GENERAL COMMENTS:

1. Changes to, or clarification of, the bid documents are only made as issued in the addenda.
2. All correspondence with respect to this project must include the State of Missouri project number as indicated above.
3. Current Plan holders list available online at: <https://www.adsplanroom.net/jobs/671/plan-holders/o1910-01-replace-escalators-elevators-west-and-east-parking-garage-capitol-building>
4. Prospective Bidders contact American Document Solutions, 1400 Forum Blvd Suite 1C, Columbia MO 65201, 573-446-7768 to order official plans and specifications.
5. **All bids shall be submitted on the revised bid form without additional terms and conditions, modifications, or stipulations. Each space on the bid form shall be properly filled including a bid amount for the alternate. Failure to do so will result in rejection of the bid.**
6. **MBE/WBE/SDVE participation requirements can be found in DIVISION 00. The MBE/WBE/SDVE participation goals are 10%/10%/3%, respectively. Only certified firms as of the bid opening date can be used to satisfy the MBE/WBE/SDVE participation goals for this project. If a bidder is unable to meet a participation goal, a Good Faith Effort Determination Form must be completed. Failure to complete this process will result in rejection of the bid.**

January 12, 2021

END OF ADDENDUM NO. 3