

## ADDENDUM NO. 2

**TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI**

**Upgrade Fire Alarm System  
Missouri Supreme Court Building  
Jefferson City, Missouri  
PROJECT NO.: O2008-01**

**Bid Opening Date: 1:30 PM, July 21, 2022 (Not Changed)**

**Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:**

### **SPECIFICATION CHANGES:**

1. Section 012300 Alternates

REPLACE Paragraph 3.1-A as follows:

- A. Base Bid: Fire alarm system shall be a fully wireless system on the second and third levels except as noted on the Drawings. Conductors for existing wiring devices on the second and third levels may be abandoned in place. Fire alarm system for the lower and first levels shall be a hybrid wired and wireless system as shown on the Drawings. Conductors shall be replaced for all new wired devices.

2. Section 015000- Construction Facilities and Temporary Controls

ADD Paragraph 1.2-D-4 as follows:

4. Existing surface protection

3. Section 015000- Construction Facilities and Temporary Controls

ADD Paragraph 3.2-E as follows:

- E. Existing Furniture, Fixtures, and Equipment: Contractor is responsible for moving, storing, and reinstalling existing furniture, fixtures, and equipment (FF&E) as required to facilitate the Work with the exception of wall-hung portraits and artwork. Removal, storage, and reinstallation of wall hung portraits and other artwork shall be the responsibility of the Owner.

4. Section 015000- Construction Facilities and Temporary Controls

ADD Paragraph 3.3-G as follows:

- G. Provide temporary wall, floor, ceiling, roof and other surface protection as required to prevent damage to existing surfaces during construction. Temporary surface protection materials and methods shall be selected based on the substrate surface protected and the construction activities performed. Contractor shall be responsible for the repair of any existing surfaces damaged during construction to return the surface to its pre-project condition.

## **DRAWING CHANGES:**

### 1. Sheet A110

CHANGE Keynote located at existing annunciator panel location in Main Lobby 1-103 in the vicinity of Fiscal Officer 1-105 from 0903.01 to 0903.02. See revised sheet A110 (attached).

### 2. Sheet E100

REPLACE General Sheet Note 2 as follows:

- 2) Base Bid: Existing conductors for fire alarm devices on this floor to be removed. Where available, existing conduits for fire alarm devices on this level may be re-used to provide conduit pathway for new fire alarm system conductors.

See revised sheet E100 (attached).

### 3. Sheet E100

REPLACE General Sheet Note 3 as follows:

- 3) Not used.

See revised sheet E100 (attached).

### 4. Sheet E101

REPLACE General Sheet Note 2 as follows:

- 2) Base Bid: Existing conductors for fire alarm devices on this floor to be removed. Where available, existing conduits for fire alarm devices on this level may be re-used to provide conduit pathway for new fire alarm system conductors.

See revised sheet E101 (attached).

### 5. Sheet E101

REPLACE General Sheet Note 3 as follows:

- 3) Not used.

See revised sheet E101 (attached).

### 6. Sheet E101

REVISE Keynote E03 within the Keynote Legend to read as follows:

E03 Annunciator panel to be demolished.

See revised sheet E101 (attached).

7. Sheet E110

DELETE all E15 keynotes on this sheet. See revised sheet E110 (attached).

8. Sheet E110

ADD Keynote E23 within the Keynote Legend and within room Marshal B-25 as follows:

E23 Remote annunciator panel(s) for both the wired and wireless fire alarm systems shall be installed within Marshall B-25. Location of panel(s) to be coordinated with Owner prior to installation. If multiple annunciator panels are required for the fire alarm system, all annunciator panels shall be located within this same room.

See revised sheet E110 (attached).

9. Sheet E111

DELETE all E15 keynotes on this sheet. See revised sheet E111 (attached).

10. Sheet E111

DELETE "Central Annunciator Panel" note and associated device symbol from Main Lobby 1-103. See revised sheet E111 (attached).

11. Sheet E501

CHANGE Location of "Central Annunciator Panel" from the Main Level to the Lower Level within the Fire Alarm Riser Detail. See revised sheet E501 (attached).

**GENERAL COMMENTS:**

(none)

**ATTACHMENTS:**

1. Sheet A110 (revised)
2. Sheet E100 (revised)
3. Sheet E101 (revised)
4. Sheet E110 (revised)
5. Sheet E111 (revised)
6. Sheet E501 (revised)

July 14, 2022

**END ADDENDUM NO. 2**