

ADDENDUM NO. 3

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

Harry S. Truman State Office Building-Renovate
Jefferson City, Missouri PROJECT NO.:
02403-01

Bid Opening Date: 1:30 PM, Thursday, April 18, 2024 (Not Changed) Bidders are hereby
informed of the following:

BID FORM CHANGES:

1. Section 004322 - Unit Prices Form:
2.0 Unit Prices - A.3
Base Bid Quantity: 10 panels
\$_____ per cubic foot

Has been revised to read, "\$_____ per square foot"

SPECIFICATION CHANGES:

NO CHANGES

DRAWING CHANGES:

NO CHANGES

GENERAL:

Question: In lieu of using the Existing/Salvaged Wall Panels, can the GC
Provide new wall framing with Vinyl Covered Gypsum Board?

Response: If new steel stud wall framing is a cost and time savings to the project, it may
be used in lieu of reusing existing panels. Wall construction must be built similarly to those
detailed for other framed wall type methods outlined in the bidding documents with a framing
method consideration that existing doors and sidelites and their frames are to be reused.
Walls shall adhere to all codes and regulations pertaining to type 2 construction. All existing
wall panels are still to be dismantled and disassembled in a way as to salvage them for
reuse. They are to be relinquished to the owner during construction. Contractor shall provide
a detailed shop drawing for suggested connections of new wall framing into existing framing
for doors and sidelites if this method is selected.

ATTACHMENTS:

NO CHANGES

April 12, 2024

END OF ADDENDUM NO. 3