

ADDENDUM NO. 3

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

**Radio Tower Replacements
MSHP Troop D and Service Center
Springfield and Carthage, Missouri
PROJECT NO.: R2001-01**

Bid Opening Date: 1:30 PM, Thursday, March 30, 2023 (Not Changed)

Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:

SPECIFICATION CHANGES:

1. Section 263200 – Backup Generator Assembly
 - a. ADD Paragraph 1.3-B as follows:
 - B. Contractor shall fill the propane tank (1,000 gallon) to ensure proper operation of the Backup Generator Assembly.
2. Section 338130 – Communications Shelter
 - a. REVISE Paragraph 1.7.as follows:
 - 1.7 Shelter design shall be stamped/sealed by a professional engineer registered in the State of Missouri.

DRAWING CHANGES:

1. Sheet A-104
 - a. ADD the following Note to Detail 1/A-104:

MoDOT will provide these dishes and the CAT-5 cable. Contractor shall install and supply tower side mounts for the dishes and the snap in hangers with inserts to properly support and secure the CAT-5 cable to the tower. For information on the type of dishes MoDOT is providing so the appropriate side mounts can be ordered, contact Shannon Johnson at (417) 291-6195 or by email at: Shannon.johnson@modot.mo.gov. MoDOT will provide the appropriate lightning suppressors to be installed inside the MSHP shelters at Carthage and Springfield.
 - b. DELETE Details 2/A-104 and 5/A-104. These are future MSHP dishes not included in this project.
2. Sheet A-108
 - a. ADD the following Note to Detail 6/A-108:

MoDOT will provide these dishes and the CAT-5 cable. Contractor shall install and supply tower side mounts for the dishes and the snap in hangers with inserts to properly support and secure the CAT-5 cable to the tower. For information on the type of dishes MoDOT is providing so the appropriate side mounts can be ordered, contact Shannon Johnson at (417) 291-6195 or by email at: Shannon.johnson@modot.mo.gov. MoDOT will provide the appropriate lightning suppressors to be installed inside the MSHP shelters at Carthage and Springfield.

3. Sheet A-201

- a. ADD the following Note to Microwave Loading Key:

MoDOT will provide the dishes and the CAT-5 cable at the 200' elevation. Contractor shall install and supply tower side mounts for the dishes and the snap in hangers with inserts to properly support and secure the CAT-5 cable to the tower. For information on the type of dishes MoDOT is providing so the appropriate side mounts can be ordered, contact Shannon Johnson at (417) 291-6195 or by email at: Shannon.johnson@modot.mo.gov. MoDOT will provide the appropriate lightning suppressors to be installed inside the MSHP shelters at Carthage and Springfield.

- b. DELETE 90' and 160' elevation dishes. These are future MSHP dishes not included in this project.

4. Sheet A-202

- a. ADD the following Note:

MoDOT will provide the dishes and the CAT-5 cable at the 200' elevation. Contractor shall install and supply tower side mounts for the dishes and the snap in hangers with inserts to properly support and secure the CAT-5 cable to the tower. For information on the type of dishes MoDOT is providing so the appropriate side mounts can be ordered, contact Shannon Johnson at (417) 291-6195 or by email at: Shannon.johnson@modot.mo.gov. MoDOT will provide the appropriate lightning suppressors to be installed inside the MSHP shelters at Carthage and Springfield.

- b. DELETE 90' and 160' elevation dishes. These are future MSHP dishes not included in this project.

5. Sheet A-206

- a. ADD the following Note to Microwave Loading Key:

MoDOT will provide the dishes and the CAT-5 cable at the 70' elevation. Contractor shall install and supply tower side mounts for the dishes and the snap in hangers with inserts to properly support and secure the CAT-5 cable to the tower. For information on the type of dishes MoDOT is providing so the appropriate side mounts can be ordered, contact Shannon Johnson at (417) 291-6195 or by email at: Shannon.johnson@modot.mo.gov. MoDOT will provide the appropriate lightning suppressors to be installed inside the MSHP shelters at Carthage and Springfield.

6. Sheet A-207

a. ADD the following Note:

MoDOT will provide the dishes and the CAT-5 cable at the 70' elevation. Contractor shall install and supply tower side mounts for the dishes and the snap in hangers with inserts to properly support and secure the CAT-5 cable to the tower. For information on the type of dishes MoDOT is providing so the appropriate side mounts can be ordered, contact Shannon Johnson at (417) 291-6195 or by email at:

Shannon.johnson@modot.mo.gov. MoDOT will provide the appropriate lightning suppressors to be installed inside the MSHP shelters at Carthage and Springfield.

GENERAL COMMENTS:

1. Bidders needing additional site inspection should contact MSHP staff James Adkins, (417) 834-2745, James.Adkins@mshp.dps.mo.gov to schedule a time to enter the facility.
2. Please contact Mandy Roberson, Contract Specialist, at (573) 522-0074, Mandy.Roberson@oa.mo.gov for questions about bidding procedures, MBE\WBE\SDVE Goals, and other submittal requirements.
3. The deadline for technical questions was March 20, 2023 at noon (12:00 PM).
4. Changes to, or clarification of, the bid documents are only made as issued in the addenda.
5. All correspondence with respect to this project must include the State of Missouri project number as indicated above.
6. Current Planholders list is available online at: [R2001-01 Radio Tower Replacements MSHP Troop D & Service Center :: Plan Holders :: State of Missouri Office of Administration \(oafmdcplanroom.com\)](https://oafmdcplanroom.com)
7. Prospective Bidders contact American Document Solutions, 1400 Forum Blvd Suite 7A, Columbia MO 65203, (573) 446-7768 to get plans and specifications.
8. **All bids shall be submitted on the bid form without additional terms and conditions, modifications, or stipulations. Each space on the bid form shall be properly filled. Failure to do so will result in rejection of the bid.**
9. **MBE/WBE/SDVE participation requirements can be found in DIVISION 00. The MBE/WBE/SDVE participation goals are 10%/10%/3%, respectively. Only certified firms as of the bid opening date can be used to satisfy the MBE/WBE/SDVE participation goals for this project. If a bidder is unable to meet a participation goal, a Good Faith Effort Determination Form must be completed. Failure to complete this process will result in rejection of the bid.**

March 22, 2023

END ADDENDUM NO. 3