

Addendum No. 02

TO: PLANS AND SPECIFICATIONS FOR:

Replace Emergency Generator
MSHP Troop I Headquarters
Rolla, MO
Project No: R2113-01

Bid Opening Date:

Unchanged: 1:30 PM, Tuesday, August 24, 2021

BIDDERS ARE HEREBY INFORMED THAT THE CONSTRUCTION PLANS AND/OR SPECIFICATIONS ARE MODIFIED AS FOLLOWS:

1. SPECIFICATIONS:

A. Section 262500 – Emergency Standby Generator

- i. ADD “AKSA” to the list of acceptable manufacturers for Emergency Standby Generators in paragraph 2.4.

2. PLANS:

A. Sheet ME-101 – Mechanical & Electrical Plans.

- i. Existing bollards relocated on plan to their actual location.
- ii. Generator shifted to accommodate location of existing bollards.
- iii. Refer to revised Sheet ME-101, attached.

B. Sheet ME-102 – Mechanical & Electrical Site Plan

- i. Generator shifted to accommodate location of existing bollards.
- ii. Refer to revised Sheet ME-102, attached.

C. Sheet ME-201 – Electrical Details and Schedules.

- i. See note added to detail #2 stating existing panel “D” is located in the boiler room in the basement.
- ii. Refer to revised Sheet ME-201, attached.

3. GENERAL:

- A. Regarding generator lead time discussion: it’s believed that there is adequate time included however this topic may be revisited at the pre-construction meeting.

4. ATTACHMENTS:

- A. Revised Sheet ME-101, dated 8/17/2021
- B. Revised Sheet ME-102, dated 8/17/2021
- C. Revised Sheet ME-201, dated 8/17/2021

END OF ADDENDUM 02