

ADDENDUM NO. 1

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

**Replace HVAC System
Troop G Headquarters Building – Missouri Highway Patrol
Willow Springs, Missouri
PROJECT NO.: R2313-01**

Bid Opening Date: 1:30 PM, Thursday April 4th, 2024 (Not Changed)

Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:

Substitution Request

1. 237416.3 Package Large Capacity Rooftop Air Conditioning Units -
 - a. *Paragraph 2.01.A.2 ADD* - Daikin Rebel

Drawing Changes

1. Drawing M3.0 - Ground Floor Mechanical New Work Plan
 - a. ADD General Note 10 – Contractor responsible for temporary heating/cooling to maintain space temperature of 65 F min and 80 F max.
2. Drawing M3.1 – First Floor Mechanical New Work Plan
 - a. ADD General Note 10 - Contractor responsible for temporary heating/cooling to maintain space temperature of 65 F min and 80 F max.

GENERAL COMMENTS:

1. A non-mandatory pre-bid meeting was held at 11:00 AM, Thursday, March 21, 2024, at MSHP Troop G HQ, Willow Springs, MO. Sign-in sheet of attendees is attached.
2. Please contact April Howser, Contract Specialist, at 573-751-0053 or April.Howser@oa.mo.gov for questions about bidding procedures, MBE\WBE\SDVE Goals, and other submittal requirements.
3. The deadline for technical questions was March 27, 2024 at Noon.
4. Changes to, or clarification of, the bid documents are only made as issued in the addenda.
5. All correspondence with respect to this project must include the State of Missouri project number as indicated above.
6. Current Plan Holders list available online at:
<https://www.oafmdcplanroom.com/jobs/2336/plan-holders/r2313-01-replace-hvac-system-troop-g-headquarters-building-mshp>
7. Prospective Bidders contact American Document Solutions, 1400 Forum Blvd Suite 7A, Columbia MO 65203, 573-446-7768 to order official plans and specifications.

8. All bids shall be submitted on the bid form without additional terms and conditions, modifications, or stipulations. Each space on the bid form shall be properly filled including a bid amount for the alternates. Failure to do so will result in rejection of the bid.
9. MBE/WBE/SDVE participation requirements can be found in DIVISION 00. The MBE/WBE/SDVE participation goals are 10%/10%/3%, respectively. Only certified firms as of the bid opening date can be used to satisfy the MBE/WBE/SDVE participation goals for this project. If a bidder is unable to meet a participation goal, a Good Faith Effort Determination Form must be completed. Failure to complete this process will result in rejection of the bid.

ATTACHMENTS:

1. Pre-Bid Meeting Sign-In Sheet March 21st 2023

END ADDENDUM NO. 1

Pre-Proposal Meeting Attendance Sheet
Replace HVAC System
MSHP Troop G HQ
Willow Springs, MO
Project No. R2313-01
3/21/24 1100

Name & Title	Company Name, Type of Contracting, MBE/WBE/SDVE Status	Phone	E-Mail Address
Chris Lloyd <i>CL</i>	OA/FMDC PM	573-526-0160	Christopher.lloyd@oa.mo.gov
Eric Poettker	McClure Eng	314-645-6232	epoettker@mcclureeng.com
Randy Duncan	OA/FMDC CA	573-526-0582	Randy.duncan@oa.mo.gov
Zach Russell	MSHP Facilities Director	573-751-2161	Zachary.russell@mshp.dps.mo.gov
LT Bair	MSHP Troop E Facilities	417-469-3121	Jeffory.bair@mshp.dps.mo.gov
<i>Bill Sandridge</i>	<i>Crawford Elect</i>	<i>870-421-6626 or 870-425-4578</i>	<i>b.sandridge@crawfordelect.com</i>

Pre-Proposal Meeting Attendance Sheet
 Replace HVAC System
 MSHP Troop G HQ
 Willow Springs, MO
 Project No. R2313-01
 3/21/24 1100

Name & Title	Company Name, Type of Contracting, MBE/WBE/SDVE Status	Phone	E-Mail Address
Wayne Williams	Troop G	417-274-9290	wayne.williams@mshp.hq.mo.gov
Building & Grounds Dustin Brown Sales	Johnson Controls, Inc. - Temperature Controls NOT MBE/WBE/SDVE	417-234-2384	dustin.w.brown@jci.com
Todd Allen Justin John Berry	MCC HVAC		
MARCOUS PRATT	MCC ELEC.	479-263-0322	mpratt@mcc-elec.net
Michael Ashem Estimator	MSI Constructors General Contractor	417-881-0903	Estimating@msiconstr.com
Blake Campbell	MSI Constructors General Contractor	417-881-0903	Estimating@msiconstr.com