

ADDENDUM NO. 1

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI:

**SECOND FLOOR ANNEX HVAC UNIT REPLACEMENT
MSHP GENERAL HEADQUARTERS COMPLEX**

1510 East Elm
Jefferson City, MO 65101
PROJECT NO. **R2314-01**

Bid Opening Date: 1:30 PM Thursday, November 2, 2023 (Not Changed)

Bidders are hereby informed that the construction plans and/or specifications are modified as follows:

SPECIFICATION CHANGES:

1. Section 237343.19 – Outdoor, Custom air-Handling Units

ADD paragraph 1.2.H

Provide factory wired UV-C lamps systems around cooling coil and condensate drain pan. Access doors into section shall have safety switches that will automatically disengage lamps when opened. Install UV-C limiting windows in access doors where UV-C lamps require access. Window's emittance levels shall to threshold limits of NIOSH and ACGIH. All items within UV-C lamp direct or indirect (reflected) lighting range shall be able to withstand exposure to UV-C light. If any material or item is not certified that item shall be shielded from UV light with UV-C resistive material. Install markings on access doors where UV-C light is present that reads: "DANGER, UV LIGHTS." Lights shall ship loose from factory.

DRAWING CHANGES:

1. Drawing M-101:

DELETE GENERAL DEMOLITION NOTES, keyed note 8.

2. Drawing M-102:

DELETE GENERAL DEMOLITION NOTES, keyed note 8.

3. Drawing M-103:

DELETE GENERAL DEMOLITION NOTES, keyed note 8.

4. Drawing M-601:

*ADD to HOT DECK, COLD DECK AIR HANDLING UNIT SCHEDULE, ACCESSORIES: note O.
UV-C LIGHTS ON COOLING COIL AND CONDENSATE DRAIN PAN.*

END ADDENDUM NO. 1