

ADDENDUM NO. 2

TO: PLANS AND SPECIFICATIONS FOR THE STATE OF MISSOURI

Replace HVAC System
Troop C Headquarters
Weldon Spring, Missouri
Project No.: R2415-01

Bid Opening Date: 1:30 PM, May 14th, 2026 (Unchanged)

Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:

SPECIFICATION CHANGES:

Section 237405

- 1) Paragraph 2.1: Add Daikin as an approved manufacturer.

DRAWING CHANGES:

None

BIDDERS QUESTIONS AND RESPONSES:

1. Is any of this work to be completed outside of normal hours M-F 7am-3:30pm

Response: No, all work will be during normal business hours.

2. Are seismic calc's and drawings required to be provided by mechanical contractor?

Response: Seismic calcs and drawings are required by contractor to be submitted with permit.

3. Will permits be required?

Response: Contractor must apply for the required Missouri Division of Fire Safety Boiler and Pressure Vessel Installation Permit..

4. Note "M" on sheet M-202 references "Pressure and Leakage Tests" – which duct is required to be tested?

- a. New high pressure duct?
- b. Inlet of the FTU's?
- c. Outlet of the FTU's

Response: Yes to all above.

5. Please consider the attached Daikin RTU substitution request for inclusion in the project

ADDENDUM NO. 2

Response: Daikin is an acceptable alternative, pending it meets the performance and power requirements scheduled. Any additional fitment adjustments (new roof curb adapter, relocation of supply and return mains, roof work, power adjustments) would be at the expense of the contractor.

GENERAL COMMENTS:

1. The Pre-Bid Meeting was held April 27, 2026, followed by a walk-through of the project site.
2. If an additional site visit is necessary, please contact Ed Georgie, 636-358-6320, robert.georgie@mshp.dps.mo.gov, who will coordinate with the on-site personnel.
3. Please contact Mandy Roberson, contract specialist, at Mandy.Roberson@oa.mo.gov for questions about bidding procedures, MBE/WBE/SDVE goals, good faith effort forms, and bid submittal requirements.
4. All bids shall be submitted on the provided bid forms without additional terms and conditions, modifications, or stipulations. Each space on the bid forms shall be properly filled. Failure to do so will result in rejection of the bid.
5. MBE/WBE/SDVE participation requirements can be found in DIVISION 00. The MBE/WBE/SDVE participation goals are 10%/10%/3%, respectively. All MBE, WBE, and SDVE contractors, subcontractors, and suppliers must be certified by the State of Missouri, Office of Equal Opportunity. No other certifications from other Missouri certifying agencies will be accepted. If a bidder is unable to meet a participation goal, a Good Faith Effort Determination Form must be completed. Failure to complete this process will result in rejection of the bid.
6. Changes to, or clarification of, the bid documents are only made as issued in the addenda.
7. All correspondence with respect to this project must include the State of Missouri project number as indicated above.
8. Current Planholders list available online at: <https://oa.mo.gov/facilities/bid-opportunities/bid-listing-electronic-plans> Prospective Bidders contact American Document Solutions, 1400 Forum Blvd Suite 7A, Columbia MO 65203, 573-446-7768 to order official plans and specifications.

ATTACHMENTS:

NONE:

END ADDENDUM NO. 2