

## ADDENDUM NO. 1

**TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI**

**Exterior LED Street Lighting  
Ike Skelton Training Site  
Jefferson City, Missouri  
PROJECT NO.: T2039-01**

**Bid Opening Date: 1:30 PM, Thursday, August 19, 2021 (Not Changed)**

**Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:**

### **SPECIFICATION CHANGES:**

1. Section 260533 – Raceway and Boxes for Electrical Systems

a. ADD Paragraph 2.3 as follows:

2.3 NONMETALLIC CONDUIT AND TUBING

A. PVC conduit shall be heavy wall, Schedule 40 ultra-violet resistant, UL listed under Standard 651. Conduit shall be suitable for use with 90 degree C insulated wire. Conduit fittings and cement shall be of the same manufacture.

B. Fittings for Schedule 40 PVC: Match to conduit or tubing type and material.

b. REVISE Paragraph 3.1-A.1 and ADD Paragraph 3.1-A.2 as follows:

1. Aboveground Conduit: Rigid Steel.
2. Underground Conduit: Schedule 40 PVC.

c. ADD Paragraph 3.1-C as follows:

C. Directional Bores: A rigid metal conduit carrier pipe shall be supplied for each PVC conduit directional bore under a roadway.

### **DRAWINGS CHANGES:**

1. Sheet G002

a. REVISE General Note 18 as follows:

18. All underground conduit shall be 1-1/4" Schedule 40 PVC unless noted otherwise.  
All above ground conduit shall be rigid metal.

2. Sheet E101

a. ADD approved product to LF-01 Tag in Light Fixture Schedule as follows:

Make: Solar Max; Model: SMX-105WiE-HV-LL5-NR-407-T202-MAR-DB.

b. ADD approved product to LF-03 Tag in Light Fixture Schedule as follows:

Make: Solar Max; Model: 75WoT-HV-L3-00-4070-T5-D-BZ-SPD10.

3. Sheet E104

a. MODIFY Alternate Bid No.1 dashed line area to include work of boring under road and installation of a junction box, at approximate Station 12+40, as part of Alternate Bid No. 1 scope of work.

4. Sheet E503

a. ADD the following General Note to Detail 2:

Seeding shall be performed from September 1 to October 15 or spring seeding may occur from March 1 to April 30. Apply hay or straw evenly over seeded areas for an application rate of 2 tons per acre.

**GENERAL COMMENTS:**

1. The Pre-Bid Meeting was held August 4, 2021 followed by a walk-through of the project site. The Pre-Bid Meeting sign-in sheet is attached.
2. Bidders who wish to perform a site inspection should contact Missouri National Guard Project Manager Joseph Schaefer at (573) 638-9500 ext 39692 or [joseph.e.schaefer10.nfg@mail.mil](mailto:joseph.e.schaefer10.nfg@mail.mil) to schedule a time to enter the facility.
3. Please contact Mandy Roberson, Contract Specialist, at (573) 522-0074, [Mandy.Roberson@oa.mo.gov](mailto:Mandy.Roberson@oa.mo.gov) for questions about bidding procedures, MBE/WBE/SDVE Goals, and other submittal requirements.
4. The deadline for technical questions is August 11, 2021.
5. Changes to, or clarification of, the bid documents are only made as issued in the addenda.
6. All correspondence with respect to this project must include the State of Missouri project number as indicated above.
7. Current Planholders list is available online at: <https://www.oafmdcplanroom.com/jobs/1011/plan-holders/t2039-01-exterior-led-street-lighting-ike-skelton-training-site>
8. Prospective Bidders contact American Document Solutions, 1400 Forum Blvd Suite 7A, Columbia MO 65203, (573) 446-7768 to get plans and specifications.
9. **All bids shall be submitted on the bid form without additional terms and conditions, modifications, or stipulations. Each space on the bid form shall be properly filled including a bid amount for each alternate. Failure to do so will result in rejection of the bid.**
10. **MBE/WBE/SDVE participation requirements can be found in DIVISION 00. The MBE/WBE/SDVE participation goals are 10% / 10% / 3% respectively. Only certified firms as of the bid opening date can be used to satisfy the MBE/WBE/SDVE participation goals for this project. If a bidder is unable to meet a participation goal, a Good Faith Effort Determination Form must be completed. Failure to complete this process will result in rejection of the bid.**

**ATTACHMENTS:**

1. Pre-Bid Meeting Sign-In Sheet

**August 10, 2021**

**END ADDENDUM NO. 1**

**Pre-Bid Meeting Attendance Sheet**  
**Exterior LED Street Lighting**  
**Ike Skelton Training Site**  
**Jefferson City, Missouri**

**Project No. T2039-01**  
**8/4/2021 & 9:00 am**

Name & Title	Company Name Type of Contracting	MBE/WBE/ SDVE Status	Phone	E-Mail Address
Paul Jeffries	Jeffries Electrical Services	—	573-680-1571	P.jeffries@jeffrieselectrical.com
Mike Robinson	Schneider Electric JC	—	573-6364101	mrbinet@secoje.com
Tim Otto	Kaiser Electric		573-824-2323	totto@kaisercentralmo.com
Jack DeCamp	Klingner	—		jdecamp@klingner.com
John Meyers	Klingner		573-355-5988	jim@klingner.com
Crazy Linhardt	Meyer Electric		573-893-2335	crazy@meyerelectric.net

**Pre-Bid Meeting Attendance Sheet**  
**Exterior LED Street Lighting**  
**Ike Skelton Training Site**  
**Jefferson City, Missouri**

**Project No. T2039-01**  
**8/4/2021 & 9:00 am**

Name & Title	Company Name Type of Contracting	MBE/WBE/ SDVE Status	Phone	E-Mail Address
Joey Schaefer	MONG		573-690-4946	joseph.e.schaefer@nrg.com
Justin Russell	Coastal electric Inc.		573-680-9148	Justin@coastalelectric.net