

ADDENDUM NO. 2

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

Paved Trail Repair Phase 2
Weston Bend State Park
Weston, Missouri
PROJECT NO. X2117-02

Bid Opening Date is: 1:30 PM, Thursday, February 26, 2026

Bidders are hereby informed that the Construction Plans and/or Specifications are modified as follows:

BID FORM CHANGES:

1. Section 004322 Unit Prices Form
 - a. REPLACE IN ITS ENTIRETY – Bidders to use REVISED Unit Price form

SPECIFICATION CHANGES:

1. NONE

DRAWING GHANGES:

1. SHEET C100
 - a. ADD General Notes 1 and 2 as follows:
 1. State Park Staff will close trail at approximately the 53+00 mark and the 99+00 mark.
 2. The Phase 1 142"x91" arch pipe culvert was designed to be installed per MoDOT 725.00C with a minimum depth of 2.0' cover over the pipe on the trail cross-section and is intended to meet HS-20 and HS-25 live loads for a 3"x1" corrugation. Any additional cover needed for construction loading would be the responsibility of the contractor and culvert cover would have to be restored to its existing condition. Contractor is responsible for verifying all existing conditions.
2. SHEET C101
 - a. ADD Demo Note #10 as follows:
 - i. Cleared trees, vegetation, and excess cut earth materials may be disposed of on top of the portions of trail that are designated for removal or are to be abandoned between the new trail segments.
 - b. ADD DEMO Note #11 as follows:
 - i. Invasive species and trees less than 9" in diameter at breast height, may be felled after March 31 deadline without bat survey, provided they are not within 150' of a known roost site.

GENERAL COMMENTS:

1. The Pre-Bid Meeting was held February 11th, 2026 followed by a walk-through of the site.
2. Bidders needing additional site inspection should contact Shanea Frederick at 913.683.8992 or shanea.frederick@dnr.mo.gov to schedule a time.
3. Please contact Mandy Roberson, Contract Specialist, at 573.690.9411 or mandy.roberson@oa.mo.gov, for questions about bidding procedures and MBE\WBE\SDVE goals and submittal requirements.
4. The deadline for technical questions was noon on February 18th, 2026.
5. Changes to, or clarification of, the bid documents are only made as issued in the addenda.
6. All correspondence with respect to this project must include the State of Missouri project number as indicated above.
7. Current Planholders list available online at:
<https://www.oafmdcplanroom.com/projects/3153/plan-holders/x2117-02-paved-trail-repair-ph-2-weston-bend-state-park>
8. Prospective Bidders contact American Document Solutions, 1400 Forum Blvd Suite 1C, Columbia MO 65201, 573-446-7768 to order official plans and specifications.
9. **All bids shall be submitted on the bid form without additional terms and conditions, modifications, or stipulations. Each space on the bid form shall be properly filled including a bid amount for each alternate. Failure to do so will result in rejection of the bid.**
10. **MBE/WBE/SDVE participation requirements can be found in DIVISION 00. The MBE/WBE/SDVE participation goals are 0%/0%/3%, respectively. Only certified firms as of the bid opening date can be used to satisfy the MBE/WBE/SDVE participation goals for this project. If a bidder is unable to meet a participation goal, a Good Faith Effort Determination Form must be completed. Failure to complete this process will result in rejection of the bid.**

ATTACHMENTS:

1. Section 004322 Unit Prices Form

February 19, 2026

END ADDENDUM NO. 2

SECTION 004322 - UNIT PRICES FORM

PROJECT NUMBER: X2117-02

1.0 Description

- A. For changing specified quantities of work from those indicated by the contract drawings and specifications, upon written instructions of Owner, the following unit prices shall prevail. The unit prices include all labor, overhead and profit, materials, equipment, appliances, bailing, shoring, shoring removal, etc., to cover the finished work of the several kinds of work called for. Only a single unit price shall be given and it shall apply for either MORE or LESS work than that shown on the drawings and called for in the specifications or included in the Base Bid. In the event of more or less units than so indicated or included during construction the total contract price shall be decreased as appropriate or increased by contract change in accordance with General Conditions Article 4.1.

2.0 Unit Prices

- A. Alternate Unit Price No. 1 – Asphalt:

- 1. Description: 6” asphalt trail with 2” BP-2 on 4” BB
- 2. Unit of Measurement: TON
- 3. Base Bid Quantity: 543 Tons

\$ _____ per ton

- B. Alternate Unit Price No. 2 – Trail Base:

- 1. Description: 4” min. rock or asphalt millings base.
- 2. Unit of Measurement: Cubic Yard
- 3. Alternate No. 1 Quantity: 177 Cubic Yards

\$ _____ per cubic yard