

ADDENDUM NO. 4

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

Upgrade Cave Electric
Onondaga Cave State Park
Leasburg, Missouri
PROJECT NO.: X2212-01

New Bid Opening Date: 1:30 PM, Thursday, September 7, 2023 (CHANGED)

Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:

SPECIFICATION CHANGES:

1. Section 001116 – INVITATION FOR BID
 - a. REVISE Paragraph 3.0-A as follows:
 - A. Until: 1:30 PM, Thursday, September 7, 2023
2. Section 260943.23 – RELAY-BASED LIGHTING CONTROLS
 - a. ADD Paragraph 1.7 E.4 as follows:
 - 1.7 E.4. Provide a laminated 11"x17" set of all drawings for each power/control panel, along with the lighting control schematic wiring diagrams for the entire cave, in the data pocket of each power/control panel.
3. Section 263613 – NON-AUTOMATIC TRANSFER SWITCHES
 - a. Paragraph 2.2 A: CHANGE "240 volts, 1-phase, 60 hertz, 3 pole, 3 wire" TO "240 volts, 1-phase, 60 hertz, 3 pole, 3 wire **with the third pole to be used for switching the system neutral**".
4. Section 263623 – AUTOMATIC TRANSFER SWITCHES
 - a. Paragraph 2.2 A: CHANGE "240 volts, 1-phase, 60 hertz, 3 pole, 3 wire" TO "240 volts, 1-phase, 60 hertz, 3 pole, 3 wire **with the third pole having an overlapping "make before break" contact for switching the system neutral**".

DRAWING CHANGES:

1. Sheet E-607
 - a. CHANGE PSU 71 lighting fixture number and type "T 18 D" TO "T 18 C".
 - b. CHANGE PSU 82 lighting fixture number and type "V 25 D", "V 26 D" and "V 27 D" TO "V 25 DS", "V 26 DS" and "V 27 DS".

GENERAL COMMENTS:

1. Please contact Mandy Roberson, Contract Specialist, at 573-522-0074 or mandy.roberson@oa.mo.gov for questions about bidding procedures, MBE\WBE\SDVE Goals, and other submittal requirements.
2. The deadline for technical questions was Tuesday, August 22, 2023 at 5:00 PM.
3. Changes to, or clarification of, the bid documents are only made as issued in the addenda.
4. All correspondence with respect to this project must include the State of Missouri project number as indicated above.
5. Current Plan holders list available online at <https://www.oafmdcplanroom.com/jobs/2091/details/x2212-01-upgrade-cave-electric-onondaga-cave-state-park>
6. Prospective Bidders contact American Document Solutions, 1400 Forum Blvd Suite 1C, Columbia MO 65201, 573-446-7768 to order official plans and specifications.
7. **All bids shall be submitted on the bid form without additional terms and conditions, modifications, or stipulations. Each space on the bid form shall be properly filled including a bid amount for the alternate. Failure to do so will result in rejection of the bid.**
8. **MBE/WBE/SDVE participation requirements can be found in DIVISION 00. The MBE/WBE/SDVE participation goals are 10%/10%/3%, respectively. Only certified firms as of the bid opening date can be used to satisfy the MBE/WBE/SDVE participation goals for this project. If a bidder is unable to meet a participation goal, a Good Faith Effort Determination Form must be completed. Failure to complete this process will result in rejection of the bid.**
9. **The Contractor shall pay not less than the prevailing hourly rate of wages for work of a similar character in the locality in which the work is performed, as determined by the Missouri Department of Labor and Industrial Relations.** Bidders are to adhere to Prevailing Wage Hourly Rate of Wages, and the Department of Labor and Industrial Relations can be contacted to determine the applicable wage rate for the work on this project.

August 29, 2023

END OF ADDENDUM NO. 4