

ADDENDUM NO. 2

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

**Water System Improvements
Stockton State Park
Dadeville, Missouri
Project No. X2323-02**

Bid Opening Date: 1:30 PM, Thursday, August 15, 2024 (Not Changed)

Bidders are hereby informed that the construction Plans and/or Specifications are modified as follows:

SPECIFICATION CHANGES:

1. Section 221220 – Portable Hydro-Pneumatic Pressure Water Tank
 - a. REVISE Paragraph 2.1-B first sentence to read “Minimum tank capacity of at least one tank shall be 2,000 gallons.”

DRAWING CHANGES:

1. Sheet C-104
 - a. DELETE 1” = 20’ scale bar at bottom right of Detail 2/Water Storage Tank Site Plan Improvements.
 - b. REPLACE annotation “PROPOSED FENCE” with “177 LF PROPOSED 8’ FENCE” on Detail 2/Water Storage Tank Site Plan Improvements.
2. Sheet E-102
 - a. ADD the following to the Luminaire Schedule:
“Approved equals: Cuesto Sol and Soltech’s Sunlike PRO 30W lighting systems.”

GENERAL COMMENTS:

1. The Pre-Bid Meeting was held on July 23, 2024 at 2:00 PM.
2. Please contact Mandy Roberson, Contract Specialist, at 573-522-0074 or Mandy.Roberson@oa.mo.gov for questions about bidding procedures, MBE\WBE\SDVE Goals, and other submittal requirements.
3. The deadline for technical questions is August 7, 2024 at 12:00 PM.
4. Changes to, or clarification of, the bid documents are only made as issued in the addenda.
5. All correspondence with respect to this project must include the State of Missouri project number as indicated above.
6. Current Plan holders list available online at <https://www.oafmdcplanroom.com/projects/2535/plan-holders/x2323-02-water-system-improvements-stockton-state-park>
7. Prospective Bidders contact American Document Solutions, 1400 Forum Blvd Suite 1C, Columbia MO 65201, 573-446-7768 to order official plans and specifications.
8. **All bids shall be submitted on the bid form without additional terms and conditions, modifications, or stipulations. Each space on the bid form shall be properly filled. Failure to do so will result in rejection of the bid.**

9. **MBE/WBE/SDVE participation requirements can be found in DIVISION 00. The MBE/WBE/SDVE participation goals are 0%/0%/3%, respectively. Only certified firms as of the bid opening date can be used to satisfy the MBE/WBE/SDVE participation goals for this project. If a bidder is unable to meet a participation goal, a Good Faith Effort Determination Form must be completed. Failure to complete this process will result in rejection of the bid.**

August 8, 2024

END OF ADDENDUM NO. 2